

District Level water Testing Laboratory, Darbhanga DLWTL

Government of Bihar

Public Health Engineering Department

District Name: Darbhanga

Sample collected by : Shah Nawaz Hussain

Date Of Sampling - 13/03/2025

Sl. No.	Block	Panchayat	Village	Location of Source	Parameters														Remarks	
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As		Total Coll
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
1	Benipur	Nagar Parasad Benipur	Bahera	Bahera Public School Bahera Darbhanga	7.68	NT	436	204	152	40	12.48	52	176	NT	NT	NT	NT	NT	NT	
Desirable limit					6.5	5.0	-	500	200	75	30	250	200	0.3	45	25	1.0	0.01		-
Permissible limit					8.5	10.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**	-

13/03/25
Chemist
P.H Division Darbhanga